Current Transformers

DER EE





ISO 9001



DE-50RCT





DE-32RCT

DE-23RCT


FEATURE

- This CT is small, light and suitable for use with electrical measuring instruments.
- The primary winding is either a cable or a busbar, which is insulated for the application voltage.
- For use with Watt.Var, Watt/Var, Watt/Watt-Hour Transducer, Meters and Relays.
- The secondary winding and ring shaped which has good electrical and mechanical prosperities.
- The fixing base can be mounted either in line with CT or transversely.

SPECIFICATION

- The standard to be followed : IEC 60044-1
- Accuracy Class: 1.0
- Rated Voltage: 0.6kV
 NOTE: The insulation level of the primary conductor determines the max. operating voltage.
- Insulation test voltage (60Hz,1min):4kV
- Rated Frequency: 50/60Hz
- Rated short-time over current: 40 times the rated primary current

	Model	Primary Current (A)	Secondary Current (A)	Typ. Rate Burden (VA)	Accuracy	А	В	С	D	Е	FØ	GØ	Н
	DE-23RCT	100~300	5	5	1.0	85.0	57.0	38.8	70	36.2	23	58.5	M5
	DE-32RCT	100~400	5	5	1.0	85.0	57.5	42.6	70	42.2	32	68.5	M5
	DE-50RCT	400~1200	5	5	1.0	100.0	59.0	50.4	85	50.2	50	85.5	M5
	DE-90RCT	1000~3000	5	5	1.0	152.0	59.0	71.8	118	75.2	90	129.4	M5



* available for DE-23RCT, DE-32RCT & DE-50RCT

得益工業儀器有限公司

DER EE

ELECTRICAL INSTRUMENT CO., LTD.

台灣23504新北市中和區中山路二段351號7F 7F, No. 351, Sec. 2, Chung Shan Rd., Chung Ho Dist., New Taipei City 23504, Taiwan TEL:886-2-2226-6789(REP) FAX:886-2-2226-7979 E-mail:deree@deree.hinet.net http://www.deree.com.tw

Specifications and appearance may be revised if needed without any prior notice. Any further product info, please contact us.